



Flexi-Force Group B.V.

Hanzeweg 25,
3771 NG Barneveld
P.O. Box 37,
3770 AA Barneveld
The Netherlands

FlexiForce Group BV in Barneveld, the Netherlands, declares that:

DECLARATION

Tecsedo SA
Repr. Mr M. Tognelli
Zona Industriale 1
6807 Taverne
Switzerland

T +31 (0)342427777
F +31 (0)342427723
T +31 (0)342427722 (dir)
E frgo@flexiforce.nl
W www.flexiforce.com

has joined the Initial Type Testing in accordance to the standard EN 13241-1 in combination with the below mentioned hardware and operators.

ITT number FlexiForce: 0402-CPD-407001 issued by SP-Institute, Sweden.

Hardware Flexi-Force BV

FlexiForce® industrial hardware components

Operators:

Marantec
MFZ
Liftmaster Professional/Chamberlain
Faac Spa
Nice Spa
Dalmatic A/S
Ovitor OY
Becker GmbH
Ditec
Mtec
BFT
Ellard

(all operators with the same construction but sold under different brand names are also a part of this type of test report.)

Obtained results:

Wind load	Class : 3
Air permeability	Class : 3
Resistance to water penetration	Class : 1
Thermal resistance without windows and pass door	U door: 0.8 W/(m ² K)
Thermal resistance with windows and pass door	U door: 1.0 W/(m ² K)

All tests are supervised and approved by Swedish National Testing and Research Institute in Sweden.

Barneveld, 18 Jun 2008
Flexi-Force Group B.V.
Frank Goedhart

INNOVATIONS FOR OVERHEAD DOORS